

Private Water Supply Testing

The following list is the series of laboratory tests needed in order to correctly specify treatment for Private Water Supplies (PWS).

When Prosep Filter Systems Ltd take responsibility for providing the analysis results, these are the series of tests carried out.

Parameter tested	Circumstance
Aluminium	All supplies
Ammonium	All supplies
Arsenic	All supplies
Clostridium perfringens	Surface waters source/influence
Coliform bacteria	All supplies
Colony counts 22 deg C	All supplies
Colony counts 37 deg C	All supplies
Colour	All supplies
Conductivity	All supplies
Copper	All supplies
E. Coli	All supplies
Enterococci	All supplies
Fluoride	All supplies
Hardness Total	All supplies
Hydrogen ion concentration (pH)	All supplies
Iron	All supplies
Lead	All supplies
Manganese	All supplies
Nitrate	All supplies
Nitrite	All supplies
Odour	All supplies
Sodium	All supplies
Sulphate	All supplies
Taste	All supplies
Turbidity	All supplies